



**COBB COUNTY  
PURCHASING DEPARTMENT**

100 Cherokee Street, Suite 260  
Marietta, Georgia 30090  
phone: (770) 528-8400 • fax: (770) 528-8428

William J. Tommie Jr., CPPO  
*Purchasing Director*

**ADDENDUM No. 2**

**Sealed Bid #17-6200  
Request for Proposal  
Design/Build Services for Splash Pad at Swift Cantrell Park  
Cobb County Parks, Recreation and Cultural Affairs Department**

**Date: October 20, 2016**

Page 1 of 2

The following addendum hereby amends and/or modifies the Proposal Documents and specifications as originally issued for this project. All proposers are subject to the provisions of this Addendum.

**This Addendum consists of:**

- Questions submitted in writing

---

**Receipt of addendum MUST be acknowledged in the submitted proposal. It is the Proposer's ultimate responsibility to ensure that they have all applicable addenda prior to bid submittal.**

**This acknowledgment form must be signed, dated, and included with your submitted proposal**

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Date

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Please Print Name

**All bids must be received before 12:00 (noon) by the Bid Opening date. Bids shall be delivered to Cobb County Purchasing Department, 122 Waddell Street, Marietta, GA 30060.**

**ADDENDUM No. 2**

**Sealed Bid #17-6200  
Request for Proposal  
Design/Build Services for Splash Pad at Swift Cantrell Park**

**Date: October 20, 2016**

**A. Questions Submitted in Writing**

- 1. Question:** The RFP calls for a pump pit. Can self priming pumps be used as typical?  
**Answer:** Yes. The main circulating pump shall be self priming with fiberglass strainer as manufactured by StaRite or approved equal. The pump shall be located in a dry pump pit in the filter/pump house at the water level elevation of the surge tank/collection tank, preferably even with the bottom of the surge/collection tank.
- 2. Question:** Integral Color is an add alternate. Can you give a basis for color? Wide range on color pricing.  
**Answer:** The integral color concrete for the alternate shall be Scofield Solachrome Integral Coloring Treatment for High-SRI Concrete or approved equal, color Cool Bimini SC42, white cement 83. Concrete mix design, batching and placement shall be in accordance with manufacturer's recommendations. Concrete shall be integral color. Color toppings or stains will not be considered.
- 3. Question:** Is any rubber safety surfacing going to be needed for on top of the splash pad area?  
**Answer:** There is no rubber safety surfacing in the project.
- 4. Question:** The Project Manual only has one electrical drawing attached. Could you please forward ALL the electrical drawings to me so that we can provide a fair and accurate pricing. I believe there should be 5 more pages that are listed in the document but were not attached.  
**Answer:** Drawing E2.0 in Addendix D of the RFP is the only electrical drawing that we have access to at this time.